## **SIEMENS**

## **Data sheet**

6EP4137-3AB00-2AY0



SITOP UPS1600/DC/24VDC/40A/IE/PN

SITOP UPS1600 40 A Ethernet/ PROFINET Uninterrupted Power supply with Ethernet/ PROFINET interface / OPC UA Server / Web server input: 24 V DC output: 24 V DC/40 A

Input	
supply voltage at DC rated value	24 V
voltage curve at input	DC
input voltage range	21 29 V DC
adjustable response value voltage for buffer connection preset	21.5 V
adjustable response value voltage for buffer connection	21 25 V; Adjustable: 21 V, 21.5 V, 22 V, 22.5 V, 23 V, 24 V, 25 V DC or via software
input current at rated input voltage 24 V rated value	46 A; for max. charging current (5 A)
Mains buffering	
type of energy storage	with batteries
design of the mains power cut bridging-connection	Adjustable range using rotary coding switch: 0.5 min, 1 min, 2 min, 5 min, 10 min, 20 min, max. buffering time or via software
charging current	0.1 A, 5 A
adjustable charging current maximum note	Automatically depending on battery module
Output	
output voltage	
<ul> <li>in normal operation at DC rated value</li> </ul>	24 V
in buffering mode at DC rated value	24 V
formula for output voltage	Vin - approx. 0.2 V
startup delay time typical	60 s
voltage increase time of the output voltage typical	60 ms
output voltage in buffering mode at DC	18.5 27 V
output current	
rated value	40 A
<ul> <li>in normal operation</li> </ul>	0 120 A
in buffering mode	0 120 A
peak current	120 A
property of the output short-circuit proof	Yes
design of short-circuit protection	Limitation to 3 x I rated for 30 ms/min; through-conductivity for 1.5 x I rated for 5 sec/min
supplied active power typical	960 W
Efficiency	

efficiency in percent	
at rated output voltage for rated value of the output	98.3 %
current typical	00.2.0/
in case of operation on rechargeable battery typical power loss [W]	98.3 %
at rated output voltage for rated value of the output	17 W
current typical	17 VV
• in case of operation on rechargeable battery typical	17 W
Protection and monitoring	
product function	
<ul> <li>reverse polarity protection against energy storage unit polarity reversal</li> </ul>	Yes
<ul> <li>reverse polarity protection against input voltage polarity reversal</li> </ul>	Yes
Signaling	
display version	
<ul><li>for normal operation</li><li>in buffering mode</li></ul>	Normal operation: LED green (OK), floating changeover contact "Bat/OK" to setting "OK" ("OK" means: Voltage of the supplying power supply unit is greater than cut-in threshold set at the DC UPS module); Lack of buffer standby: LED red (alarm), floating changeover contact "Alarm/Bat" to setting "Alarm"; Battery replacement required: LED red (alarm) flashing with approx. 0.25 Hz, floating changeover contact "Alarm/Bat" switching with approx. 0.25 Hz; Energy storage > 85%: LED green (Bat > 85%), floating NO contact "Bat > 85" closed; Permissible contact current capacity: DC 60 V/1 A or AC 30 V /1 A  Buffered mode: LED yellow (Bat), floating and alargeover contact "OK/Bat"
	to setting "Bat"; Prewarning battery voltage < 20.4 VDC: LED red (alarm), floating changeover contact "Alarm/Bat" to setting "Alarm"; Energy storage > 85%: LED green (Bat > 85%), floating NO contact "Bat > 85" closed
Interface	
product component PC interface	Yes
design of the interface	Ethernet/PROFINET
Safety	
Safety galvanic isolation between input and output	No
Safety galvanic isolation between input and output operating resource protection class	
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III
galvanic isolation between input and output operating resource protection class certificate of suitability  • CE marking	No Class III Yes
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III
galvanic isolation between input and output operating resource protection class certificate of suitability  • CE marking • as approval for USA • relating to ATEX	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01)
galvanic isolation between input and output operating resource protection class certificate of suitability  • CE marking • as approval for USA • relating to ATEX  • C-Tick type of certification CB-certificate	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes
galvanic isolation between input and output operating resource protection class certificate of suitability  • CE marking  • as approval for USA  • relating to ATEX  • C-Tick type of certification CB-certificate shipbuilding approval	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL
galvanic isolation between input and output operating resource protection class certificate of suitability  CE marking as approval for USA relating to ATEX  C-Tick type of certification CB-certificate shipbuilding approval protection class IP	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes
galvanic isolation between input and output operating resource protection class certificate of suitability • CE marking • as approval for USA • relating to ATEX  • C-Tick type of certification CB-certificate shipbuilding approval protection class IP  EMC	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 Gc; ATEX (EX) II 3G EX NA NC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX NA NC IIC T4 GC; ATEX (EX) II 3G EX NA NC IIC T4 GC; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2
galvanic isolation between input and output operating resource protection class certificate of suitability  • CE marking • as approval for USA • relating to ATEX  • C-Tick  type of certification CB-certificate shipbuilding approval protection class IP  EMC  standard • for emitted interference • for interference immunity  environmental conditions ambient temperature • during operation • during transport	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2  -25 +70 °C; with natural convection -40 +85 °C
galvanic isolation between input and output operating resource protection class certificate of suitability  • CE marking • as approval for USA • relating to ATEX  • C-Tick  type of certification CB-certificate shipbuilding approval protection class IP  EMC  standard • for emitted interference • for interference immunity  environmental conditions  ambient temperature • during operation • during transport • during storage	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2  -25 +70 °C; with natural convection -40 +85 °C -40 +85 °C
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2  -25 +70 °C; with natural convection -40 +85 °C
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2  -25 +70 °C; with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2  -25 +70 °C; with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation
galvanic isolation between input and output operating resource protection class certificate of suitability	No Class III  Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 IECEX EX nA nC IIC T4 Gc; ATEX (EX) II 3G EX nA nC IIC T4 Gc; cULus Class I, Div. 2 (ANSI/ISA-12.12.01-2015, CSA C22.2 No. 213-15) Group ABCD, T4; cCSAus (CSA C22.2 No. 213, ANSI/ISA-12.12.01) Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, DNV GL IP20  EN 55022 Class B EN 61000-6-2  -25 +70 °C; with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation

<ul> <li>for control circuit and status message</li> </ul>	14 screw terminals for 0.2 1.5 mm²/24 16 AWG
width of the enclosure	70 mm
height of the enclosure	139 mm
depth of the enclosure	150 mm
required spacing	
• top	50 mm
• bottom	50 mm
• left	0 mm
• right	0 mm
net weight	0.7 kg
product feature of the enclosure housing can be lined up	Yes
fastening method	Snaps onto DIN rail EN 60715 35x7.5/15
electrical accessories	Battery module
MTBF at 40 °C	318 776 h
reference code acc. to IEC 81346-2	Т
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)

